



BIDDER QUESTION #4

Engineer's Response to Request for Information

Project: San Lorenzo Valley Water District / Probation Tank Replacement

RFI No: B - 004

Requested by: Crosno Construction Inc.

Date Received: April 9, 2018

Regarding: Tank Coating Contractor Qualifications

Response

The tank coating contractor qualification for this project on sheet T3.0, Tank Coating in the Qualifications Section, Item 1: "Contractor engaged in surface preparation and coating application shall be certified according to SSPC-QP 1."

This qualification requirement will not be modified or waived.

Signed By:

Date: 04/13/18