



# MME

CIVIL + STRUCTURAL ENGINEERING • SINCE 1987

## BIDDER QUESTION #1

### Engineer's Response to Request for Information

Project: San Lorenzo Valley Water District / Probation Tank Replacement

RFI No: B - 001

Requested by: Superior Hydroseeding, Inc.

Date Received: March 21, 2018

Regarding: Bid Item #19 - Revegetation

#### Response

Revegetation will occur per a restoration plan developed during construction and implemented after construction is completed on a separate contract.

Please exclude hydroseeding or any other revegetation from your bid.

All items for erosion control shall be included under bid item #2. Due to a restriction on the use of landscaping elements, please substitute 3" of rice straw certified weed free, with minor areas of erosion control blanket on 2H:1V slopes to provide temporary erosion control during construction.

MME will issue an addendum further clarifying the elimination of bid item #19 revegetation from the project scope and the substitution for 3" of rice straw, certified weed free in place of erosion control blanket on slopes less than 2H:1V.

Signed By:

Date: 03/28/18