



BIDDER QUESTION #12

Engineer's Response to Request for Information

Project: San Lorenzo Valley Water District / Probation Tank Replacement

RFI No: B - 012

Requested by: CRW Industries, Inc.

Date Received: April 25, 2018

Regarding: SCADA Installation

Response

The contractor will be responsible to mount SCADA equipment to the new tank as directed by SLVWD and contract documents. The contractor will be responsible to coordinate with Emerson personnel during installation and start up. Emerson personnel will program the system hardware and provide onsite support during installation and start up assistance.

Signed By:

Date: 04/27/18